


Summary


\$13,621 Monthly Energy Cost Savings	66,343 Elec. Savings (kWh/mo)	13% Elec. Savings (%)	469,877 R12M Electricity Savings (kWh/yr)	12,406 CO2e Savings (kg/mo)
\$133,287 R12M Energy Cost Savings	17,947 Gas. Savings (kWh/mo)	50% Gas. Savings (%)	557,431 R12M Gas Savings (kWh/yr)	182,494 R12M CO2e Savings (kg/yr)


Total Energy (kWh/Month)





Summary








Summary


Cumulative Energy Savings (kWh)




Note, cumulative savings are calculated starting July 2018



Summary



Note, cumulative savings are calculated starting July 2018





Civic Centre

\$4,179	23,635	84%	303,037	3,096
Monthly Energy Cost Savings	Elec. Savings (kWh/mo)	Elec. Savings (%)	R12M Electricity Savings (kWh/yr)	CO2e Savings (kg/mo)
ΦEO 11/				20 /22
\$58,116 R12M Energy Cost Savings				39,423 R12M CO2e Savings (kg/yr)


Comments:

The baseline for the Civic Centre has been updated, the baseline period was selected as Dec-2020 to Nov-2021, in order to exclude months where refurbishment was taking place.

Electricity use continues to be less than baseline for 2023, the Civic Centre renovation has displaced many office workers, which has decreased electricity demand.


Electric vehicle charging stations have been in use from March 2021, non-routine adjustments are on-going to account for the increased electricity use.


Civic Centre Electricity Use Compared to Baseline (kWh)







Civic Centre












Civic Centre






Aquatic Centre

\$2,193 Monthly Energy Cost Savings	3,729 Elec. Savings (kWh/mo)	3% Elec. Savings (%)	-65,090 R12M Electricity Savings (kWh/yr)	4,501 CO2e Savings (kg/mo)
\$28,352 R12M Energy Cost Savings	19,385 Gas. Savings (kWh/mo)	100% Gas. Savings (%)	572,865 R12M Gas Savings (kWh/yr)	115,791 R12M CO2e Savings (kg/yr)

Comments:

Electricity and natural gas baselines have been updated for the Aquatic Centre, the baseline period is May 2021 to June 2022 and excludes Aug. and Sept. 2021 due to changes in Covid-19 alert levels and partial closure. The outdoor pool is open year-round and the baseline reflects this change.


Electricity use was less than expected in March 2023. The Aquatic Centre did not use any gas this month, the boilers have been turned off since 17 December. The EUI for the month is lower than the average for the past 12 months, which is excellent.






Aquatic Centre

Aquatic Centre Natural Gas Compared to Baseline (kWh)





Aquatic Centre Carbon Emissions Compared to Baseline (kg CO2e)





Aquatic Centre








Te Koputu Library

-\$598 Monthly Energy Cost Savings	-2,344 Elec. Savings (kWh/mo)	-18% Elec. Savings (%)	2,324 R12M Electricity Savings (kWh/yr)	-746 CO2e Savings (kg/mo)
\$124 R12M Energy Cost Savings	-2,120	- 18%	-10,104	-1,784
	Gas. Savings (kWh/mo)	Gas. Savings (%)	R12M Gas Savings (kWh/yr)	R12M CO2e Savings (kg/yr)

Comments:


New baselines were established for electricity and natural gas at the Library, the baseline period is July 2021 to June 2022 and use cooling degree days as the independent variable.


Electricity and natural gas use were more than expected for the month. The average daily temperature in March 2023 was approximately one degree cooler than March 2022, March was also a relatively humid month, averaging 93% humidity at 9am.






Te Koputu Library












Te Koputu Library











Museum and Research Centre


-\$264 Monthly Energy Cost Savings	-1,248 Elec. Savings (kWh/mo)	-14% Elec. Savings (%)	3,618 R12M Electricity Savings (kWh/yr)	-257 CO2e Savings (kg/mo)
\$1,742 R12M Energy Cost Savings	-452 Gas. Savings (kWh/mo)	- 16% Gas. Savings (%)	10,950 R12M Gas Savings (kWh/yr)	2,843 R12M CO2e Savings (kg/yr)

Comments:

New baselines were established for electricity and natural gas at the Museum and Research Centre, the baseline period is July 2021 to June 2022. The electricity baseline uses cooling degree days as the independent variable and the natural gas baseline uses heating degree days as the independent variable.

Natural gas and electricity use was higher than expected, which is likely due to dehumidification requirements.


Museum Research Centre Electricity Use Compared to Baseline (kWh)






Museum and Research Centre

Museum Research Centre Natural Gas Compared to Baseline (kWh)





Museum Research Centre Carbon Emissions Compared to Baseline (kg CO2e)






Museum and Research Centre





Museum Research Centre Rolling 12 Month Savings





War Memorial Hall


\$381 Monthly Energy Cost Savings	1,591 Elec. Savings (kWh/mo)	26% Elec. Savings (%)	18,370 R12M Electricity Savings (kWh/yr)	443 CO2e Savings (kg/mo)
\$2,508 R12M Energy Cost Savings	1,133 Gas. Savings (kWh/mo)	48% Gas. Savings (%)	-16,281 R12M Gas Savings (kWh/yr)	-1,088 R12M CO2e Savings (kg/yr)

Comments:

The baseline was updated for War Memorial Hall, the baseline adjusts for ambient temperature. The baseline period is July 2021 to June 2022. The War Memorial Hall uses more electricity and gas in winter months.

The War Memorial Hall has NHH accounts for both natural gas and electricity. Some months' usage may be estimated by the retailer and captured by a subsequent meter reading. It is recommended that manual meter readings are taken, which would improve accuracy of electricity and gas usage.


The War Memorial Hall has achieved significant gas and electricity savings from January to March 2023. December 2022 used more electricity than expected, this may be partly due to when the electricity meter was read, The War Memorial Hall may have also seen higher occupancy in December with holiday events.






War Memorial Hall

War Memorial Hall Natural Gas Compared to Baseline (kWh)




War Memorial Hall Carbon Emissions Compared to Baseline (kg CO2e)






War Memorial Hall

War Memorial Hall Energy Use Index by Month Compared to Rolling 12-Month Values







Water Treatment Plant


\$4,508	25,759	20%	148,443	3,374
Monthly Energy Cost Savings	Elec. Savings (kWh/mo)	Elec. Savings (%)	R12M Electricity Savings (kWh/yr)	CO2e Savings (kg/mo)
\$25,259				19,495
R12M Energy Cost Savings				R12M CO2e Savings (kg/yr)

Comments:

The electricity use baseline was updated for the Water Treatment Plant, the baseline period is July 2021 to June 2022. The electricity baseline uses the amount of water pumped (m³) as the independent variable.

Another month of good savings has been achieved at the WTP in March 2023. The monthly EUI is less than the average over the last 12 months and rolling 12-month savings are increasing, which is excellent. Less water has been treated in March 2023 compared to March 2022.









Water Treatment Plant

Water Treatment Plant Carbon Emissions Compared to Baseline (kg CO2e)








Water Treatment Plant

Water Treatment Plant Energy Use Index by Month Compared to Rolling 12-Month Values



● EUI Monthly (kWh/m^3) ● EUI R12M (kWh/m^3)




Braemar Road Pump Station

\$109	618	1%	19,248	81
Monthly Energy Cost Savings	Elec. Savings (kWh/mo)	Elec. Savings (%)	R12M Electricity Savings (kWh/yr)	CO2e Savings (kg/mo)
\$4,347				2,627
R12M Energy Cost Savings				R12M CO2e Savings (kg/yr)

Comments:

The electricity use baseline was updated for the Braemar Road Pump Station, the baseline period is July 2021 to June 2022. The electricity baseline uses the amount of water pumped (m³) as the independent variable.


Savings from the high efficiency pumps and motors will no longer be visible when comparing to the new baseline and rolling 12-month savings will decrease. However, real savings have been achieved since September 2020, using approximately 15% less electricity compared to the older pumps and motors, which is evident in the EUI chart.






Braemar Road Pump Station












Braemar Road Pump Station





● EUI Monthly (kWh/m^3) ● EUI R12M (kWh/m^3)




Paul Road Pump Station

-\$124	-696	-1%	1,787	-91
Monthly Energy Cost Savings	Elec. Savings (kWh/mo)	Elec. Savings (%)	R12M Electricity Savings (kWh/yr)	CO2e Savings (kg/mo)
\$227				248
R12M Energy Cost Savings				R12M CO2e Savings (kg/yr)

Comments:

The electricity use baseline was updated for the Paul Road Pump Station, the baseline period is July 2021 to June 2022. The electricity baseline uses the amount of water pumped (m³) as the independent variable. The updated baseline has a smaller baseload factor and a larger variable component.


Electricity use was slightly more than expected at Paul Road Pump Station. The monthly EUI is above average over the past 12 months. Rolling 12 month savings are increasing and are positive for the first time in several years, which is good.






Paul Road Pump Station






Paul Rd Pumps Rolling 12 Month Savings





Paul Road Pump Station





● EUI Monthly (kWh/m^3) ● EUI R12M (kWh/m^3)



Johnson Road Pump Station


\$562	2,613	35%	35,883	342
Monthly Energy Cost Savings	Elec. Savings (kWh/mo)	Elec. Savings (%)	R12M Electricity Savings (kWh/yr)	CO2e Savings (kg/mo)
\$7,775				4,678
R12M Energy Cost Savings				R12M CO2e Savings (kg/yr)

Comments:

The electricity use baseline was updated for the Johnson Road Pump Station, the baseline period is Aug 2018 to June 2022. The electricity baseline uses the amount of water pumped (m³) as the independent variable. The updated baseline has a smaller baseload factor and a larger variable component.

Another good month of savings for the month at Johnson Rd Pump Station, using 35% less electricity than expected.

Johnson Rd Pumps Electricity Use Compared to Baseline (kWh)




\$10,000




Whakatane District Council

Johnson Road Pump Station












Johnson Road Pump Station

Johnson Rd Pumps Energy Use Index by Month Compared to Rolling 12-Month Values



● EUI Monthly (kWh/m^3) ■ EUI R12M (kWh/m^3)



Johnson and Braemar Rd Pump Stations


231 5%	55,131	423
s (kWh/mo) Elec. Savings	(%) R12M Electricity Savings (kV	Vh/yr) CO2e Savings (kg/mo)
		7,305
		R12M CO2e Savings (kg/yr)

Comments:

Baselines were updated for Johnson Road and Braemar Road pump stations.

Johnson Rd achieved savings in March 2023, Braemar Rd pump station's electricity use slightly less than expected for the month. The monthly EUI for the two pumps has shown a trend of decreasing energy use in recent months, which is good.


Johnson and Braemar Rd Pump Stations Electricity Use Compared to Baseline (kWh)






Johnson and Braemar Rd Pump Stations

Johnson and Braemar Rd Pump Stations Carbon Emissions Compared to Baseline (kWh)








Johnson and Braemar Rd Pump Stations

Johnson and Braemar Rd Pump Stations Energy Use Index by Month





Bridger Glade Pump Station


\$411	2,329	17%	7,351	305
Monthly Energy Cost Savings	Elec. Savings (kWh/mo)	Elec. Savings (%)	R12M Electricity Savings (kWh/yr)	CO2e Savings (kg/mo)
\$1,288 R12M Energy Cost Savings				966 R12M CO2e Savings (kg/yr)
R12M Energy Cost Savings				R12M CO2e Savings (kg/y

Comments:

The electricity use baseline was updated for the Bridger Glade Pump Station, the baseline period is July 2021 to June 2022. The electricity baseline uses the amount of water pumped (m³) as the independent variable. The updated baseline has no baseload factor and a marginally larger variable component.

March is the seventh month in a row that the Bridger Glade Pump Station has used less electricity than expected, this is due to new supply pumps that were installed in late August 2022. The monthly EUI is less than average over the last 12 months.


Bridger Glade Pumps Electricity Use Compared to Baseline (kWh)






Bridger Glade Pump Station











Bridger Glade Pump Station





● EUI Monthly (kWh/m^3) ● EUI R12M (kWh/m^3)



Ohope Oxidation Ponds


\$79	449	3%	-8,998	59
Monthly Energy Cost Savings	Elec. Savings (kWh/mo)	Elec. Savings (%)	R12M Electricity Savings (kWh/yr)	CO2e Savings (kg/mo)
-\$1,572 R12M Energy Cost Savings				-1,186 R12M CO2e Savings (kg/yr)

Comments:

The baseline for electricity use was updated for the Ohope Oxidation Ponds, the baseline period is July 2021 to June 2022. The electricity baseline uses the amount of effluent pumped (m^3) as the independent variable. The updated baseline has a larger baseload factor and a smaller variable component.

Ohope Oxidation Ponds have used more electricity than expected in 7 of the last 12 months. Rainfall has generally been higher than usual, which may contribute to higher electricity usage.


Ohope Oxidation Ponds Electricity Use Compared to Baseline (kWh)






Ohope Oxidation Ponds












Ohope Oxidation Ponds

Ohope Oxidation Ponds Energy Use Index by Month Compared to Rolling 12-Month Values






Whakatane Oxidation Ponds

\$183	996	3%	-4,370	130
Monthly Energy Cost Savings	Elec. Savings (kWh/mo)	Elec. Savings (%)	R12M Electricity Savings (kWh/yr)	CO2e Savings (kg/mo)
-\$538				- 595
R12M Energy Cost Savings				R12M CO2e Savings (kg/yr)

Comments:

The electricity use baseline was updated for the Whakatane Oxidation Ponds, the baseline period is July 2021 to June 2022. The electricity baseline combines electricity use for the NHH and TOU account and uses the effluent volumes each month (m^3) as the independent variable. The updated baseline has a smaller baseload factor and a smaller variable component.


The oxidation ponds' electricity use is less than expected in March 2023. The monthly EUI has increased above the 12 month average; however, the 12 month average EUI is trending downwards, which is good.






Whakatane Oxidation Ponds











Whakatane Oxidation Ponds

Whakatane Oxidation Ponds Energy Use Index by Month Compared to Rolling 12-Month Values





McAlister Street and Rose Garden Pump Stations


\$6	-1,672	-28%	-12,948	-219
Monthly Energy Cost Savings	Elec. Savings (kWh/mo)	Elec. Savings (%)	R12M Electricity Savings (kWh/yr)	CO2e Savings (kg/mo)
\$1,792 R12M Energy Cost Savings				-1,705 R12M CO2e Savings (kg/yr)

Comments:

The baseline for McAlister St and Rose Garden Pumps was updated, the baseline adjusts for the amount of rainfall at the Kopeopeo weather station. Expected electricity is for McAlister St and Rose Gardens combined. The baseline period uses data from July 2021 to June 2022. The updated baseline uses a smaller baseload and a marginally smaller variable component.

The pump stations used more electricity than expected this month. March 2023 was a moderate to high rainfall month. Approximately 130mm of rain coincided within the billing period.


McAlister and Rose Garden Pumps Electricity Use Compared to Baseline (kWh) 20,000






McAlister Street and Rose Garden Pump Stations












Murupara Pools

\$1,994 Monthly Energy Cost Savings	10,583 Elec. Savings (kWh/mo)	42% Elec. Savings (%)	21,220 R12M Electricity Savings (kWh/yr)	1,386 CO2e Savings (kg/mo)
\$3,868 R12M Energy Cost Savings				2,780 R12M CO2e Savings (kg/yr)

Comments:

Murupara Pools have been added to reporting in December 2022. The baseline period uses data from July 2021 to June 2022 and adjusts for ambient temperature as well as how many days in the month the pool is open or closed.

The pools used less electricity than expected in March 2023, even though it was a cooler month compared to previous seasons, which usually requires more electricity for heating.




2023



Whakatane District Council

2020

Murupara Pools





2022

2021

