


Summary

\$12,441 Monthly Energy Cost Savings	63,036 Elec. Savings (kWh/mo)	14% Elec. Savings (%)	480,899 R12M Electricity Savings (kWh/yr)	10,997 CO2e Savings (kg/mo)
\$127,088 R12M Energy Cost Savings	13,235 Gas. Savings (kWh/mo)	43% Gas. Savings (%)	459,209 R12M Gas Savings (kWh/yr)	162,530 R12M CO2e Savings (kg/yr)

Total Energy (kWh/Month)



Ohope Oxidation PondsMuseum Research Centre

Bridger Glade PumpsWar Memorial Hall

Johnson Rd Pumps

Murupara Pools

Civic Centre

McAlister and Rose Garden Pumps




Whakatane District Council

Summary

4,568 (8%)

5,487 (10%)

5,908 (11%) —




12,409 (22%)



Summary

Cumulative Energy Savings (kWh)




Note, cumulative savings are calculated starting July 2018




Summary

Cumulative Energy Cost Savings (\$)



Note, cumulative savings are calculated starting July 2018





Civic Centre

\$3,778		21,731	81%	300,045	2,847
Monthly Energy Cost	Savings	Elec. Savings (kWh/mo)	Elec. Savings (%)	R12M Electricity Savings (kWh/yr)	CO2e Savings (kg/mo)
\$56,879 R12M Energy Cost S	avings				39,115 R12M CO2e Savings (kg/yr)
	3				


Comments:

The baseline for the Civic Centre has been updated, the baseline period was selected as Dec-2020 to Nov-2021, in order to exclude months where refurbishment was taking place.

Electricity use continues to be less than baseline for 2023, the Civic Centre renovation has displaced many office workers, which has decreased electricity demand.

Electric vehicle charging stations have been in use from March 2021, non-routine adjustments are on-going to account for the increased electricity use.


Civic Centre Electricity Use Compared to Baseline (kWh)





Civic Centre












Civic Centre





Aquatic Centre


\$2,600 Monthly Energy Cost Savings	8,951 Elec. Savings (kWh/mo)	8% Elec. Savings (%)	-42,715 R12M Electricity Savings (kWh/yr)	3,856 CO2e Savings (kg/mo)
\$25,772 R12M Energy Cost Savings	12,966 Gas. Savings (kWh/mo)	93% Gas. Savings (%)	476,285 R12M Gas Savings (kWh/yr)	97,592 R12M CO2e Savings (kg/yr)

Comments:

Electricity and natural gas baselines have been updated for the Aquatic Centre, the baseline period is May 2021 to June 2022 and excludes Aug. and Sept. 2021 due to changes in Covid-19 alert levels and partial closure. The outdoor pool is open year-round and the baseline reflects this change.

Electricity use was less than expected in April 2023. The Aquatic Centre used very little gas this month, the boilers were switched off from 17 December and heating has been primarily provided by heat pumps. The EUI for the month is lower than the average for the past 12 months, which is excellent.









Aquatic Centre

Aquatic Centre Natural Gas Compared to Baseline (kWh)





Aquatic Centre Carbon Emissions Compared to Baseline (kg CO2e)






Aquatic Centre










Te Koputu Library

-\$58 Monthly Energy Cost Savings	-399 Elec. Savings (kWh/mo)	-3% Elec. Savings (%)	- 1,340 R12M Electricity Savings (kWh/yr)	-17 CO2e Savings (kg/mo)
-\$485 R12M Energy Cost Savings	171	1%	-7,717	-1,745
	Gas. Savings (kWh/mo)	Gas. Savings (%)	R12M Gas Savings (kWh/yr)	R12M CO2e Savings (kg/yr)

Comments:


New baselines were established for electricity and natural gas at the Library, the baseline period is July 2021 to June 2022 and use cooling degree days as the independent variable.


Electricity use was more than expected for the month, natural gas use was less than expected. The average daily temperature in April 2023 was approximately one degree warmer than April 2022,. April 2023 was a less humid month compared to March 2023, 7% less relative humidity on average.






Te Koputu Library













Te Koputu Library











Museum and Research Centre


-\$19 Monthly Energy Cost Savings	84 Elec. Savings (kWh/mo)	1% Elec. Savings (%)	3,472 R12M Electricity Savings (kWh/yr)	-77 CO2e Savings (kg/mo)
\$1,398 R12M Energy Cost Savings	-427 Gas. Savings (kWh/mo)	-15% Gas. Savings (%)	6,788 R12M Gas Savings (kWh/yr)	1,927 R12M CO2e Savings (kg/yr)

Comments:

New baselines were established for electricity and natural gas at the Museum and Research Centre, the baseline period is July 2021 to June 2022. The electricity baseline uses cooling degree days as the independent variable and the natural gas baseline uses heating degree days as the independent variable.

Natural gas use was 15% higher than expected, which may be due to dehumidification requirements. Natural gas use has remained relatively flat from December 2022. Energy use for the month is close to average over the last 12 months.


Museum Research Centre Electricity Use Compared to Baseline (kWh)






Museum and Research Centre

Museum Research Centre Natural Gas Compared to Baseline (kWh)





Museum Research Centre Carbon Emissions Compared to Baseline (kg CO2e)






Museum and Research Centre





Museum Research Centre Rolling 12 Month Savings





War Memorial Hall


-\$105 Monthly Energy Cost Savings	-814 Elec. Savings (kWh/mo)	-24% Elec. Savings (%)	-4,304 R12M Electricity Savings (kWh/yr)	2 CO2e Savings (kg/mo)
-\$1,767 R12M Energy Cost Savings	524 Gas. Savings (kWh/mo)	24% Gas. Savings (%)	-16,147 R12M Gas Savings (kWh/yr)	-4,034 R12M CO2e Savings (kg/yr)

Comments:

The baseline was updated for War Memorial Hall, the baseline adjusts for ambient temperature. The baseline period is July 2021 to June 2022. The War Memorial Hall uses more electricity and gas in winter months, the change in baseline can be observed in monitoring starting July 2022.

The War Memorial Hall has used more electricity than expected in the past three months. December 2022 used more electricity than expected and January 2023 used less,, this may be partly due to when the electricity meter was read, The War Memorial Hall may have also seen higher occupancy in December with holiday events.


The hall has used less natural gas than expected since October 2022, which is excellent.






War Memorial Hall

War Memorial Hall Natural Gas Compared to Baseline (kWh)




War Memorial Hall Carbon Emissions Compared to Baseline (kg CO2e)






War Memorial Hall

War Memorial Hall Energy Use Index by Month Compared to Rolling 12-Month Values







Water Treatment Plant


\$5,194	29,727	24%	194,119	3,894
Monthly Energy Cost Savings	Elec. Savings (kWh/mo)	Elec. Savings (%)	R12M Electricity Savings (kWh/yr)	CO2e Savings (kg/mo)
\$33,792				25,442
R12M Energy Cost Savings				R12M CO2e Savings (kg/yr)

Comments:

The electricity use baseline was updated for the Water Treatment Plant, the baseline period is July 2021 to June 2022. The electricity baseline uses the amount of water pumped (m³) as the independent variable.

Another month of savings has been achieved at the WTP in April 2023. Water metering errors were present from 2 April to 10 April and a non routine adjustment was required.


Water Treatment Plant Electricity Use Compared to Baseline (kWh)






Water Treatment Plant

Water Treatment Plant Carbon Emissions Compared to Baseline (kg CO2e)








Water Treatment Plant

Water Treatment Plant Energy Use Index by Month Compared to Rolling 12-Month Values



● EUI Monthly (kWh/m^3) ● EUI R12M (kWh/m^3)




Braemar Road Pump Station

-\$86	-489	-1%	10,450	-64
Monthly Energy Cost Savings	Elec. Savings (kWh/mo)	Elec. Savings (%)	R12M Electricity Savings (kWh/yr)	CO2e Savings (kg/mo)
\$2,489				1,479
R12M Energy Cost Savings				R12M CO2e Savings (kg/yr)

Comments:

The electricity use baseline was updated for the Braemar Road Pump Station, the baseline period is July 2021 to June 2022. The electricity baseline uses the amount of water pumped (m³) as the independent variable.


Savings from the high efficiency pumps and motors will no longer be visible when comparing to the new baseline and rolling 12-month savings will decrease. However, real savings have been achieved since September 2020, using approximately 15% less electricity compared to the older pumps and motors, which is evident in the EUI chart.






Braemar Road Pump Station











Braemar Road Pump Station





● EUI Monthly (kWh/m^3) ● EUI R12M (kWh/m^3)




Paul Road Pump Station

\$273	1,541	4%	5,144	202
Monthly Energy Cost Savings	Elec. Savings (kWh/mo)	Elec. Savings (%)	R12M Electricity Savings (kWh/yr)	CO2e Savings (kg/mo)
\$888				682
R12M Energy Cost Savings				R12M CO2e Savings (kg/yr)

Comments:

The electricity use baseline was updated for the Paul Road Pump Station, the baseline period is July 2021 to June 2022. The electricity baseline uses the amount of water pumped (m³) as the independent variable. The updated baseline has a smaller baseload factor and a larger variable component.


Electricity use was slightly less than expected at Paul Road Pump Station. The monthly EUI is below average over the past 12 months. Rolling 12 month savings are increasing and from March 2023 are positive for the first time in several years, which is good.






Paul Road Pump Station











Paul Road Pump Station





● EUI Monthly (kWh/m^3) ● EUI R12M (kWh/m^3)



Johnson Road Pump Station


\$620	2,881	38%	35,397	377
Monthly Energy Cost Savings	Elec. Savings (kWh/mo)	Elec. Savings (%)	R12M Electricity Savings (kWh/yr)	CO2e Savings (kg/mo)
\$7,653				4,622
R12M Energy Cost Savings				R12M CO2e Savings (kg/yr)

Comments:

The electricity use baseline was updated for the Johnson Road Pump Station, the baseline period is Aug 2018 to June 2022. The electricity baseline uses the amount of water pumped (m³) as the independent variable. The updated baseline has a smaller baseload factor and a larger variable component.

Another good month of savings for the month at Johnson Rd Pump Station, using 38% less electricity than expected.


Johnson Rd Pumps Electricity Use Compared to Baseline (kWh)






Johnson Road Pump Station










Johnson Road Pump Station

Johnson Rd Pumps Energy Use Index by Month Compared to Rolling 12-Month Values





Johnson and Braemar Rd Pump Stations


\$534	2,392	5%	45,847	313
Monthly Energy Cost Savings	Elec. Savings (kWh/mo)	Elec. Savings (%)	R12M Electricity Savings (kWh/yr)	CO2e Savings (kg/mo)
\$10,141				6,101
R12M Energy Cost Savings				R12M CO2e Savings (kg/yr)

Comments:

Baselines were updated for Johnson Road and Braemar Road pump stations.

Johnson Rd achieved savings in April 2023, Braemar Rd pump station's electricity use was slightly more than expected for the month. The monthly EUI for the two pumps in March and April has been slightly higher than the six previous months.


Johnson and Braemar Rd Pump Stations Electricity Use Compared to Baseline (kWh)






Johnson and Braemar Rd Pump Stations

Johnson and Braemar Rd Pump Stations Carbon Emissions Compared to Baseline (kWh)








Johnson and Braemar Rd Pump Stations

Johnson and Braemar Rd Pump Stations Energy Use Index by Month





Bridger Glade Pump Station


\$279	1,582	11%	8,903	207
Monthly Energy Cost Savings	Elec. Savings (kWh/mo)	Elec. Savings (%)	R12M Electricity Savings (kWh/yr)	CO2e Savings (kg/mo)
\$1,561				1,169
R12M Energy Cost Savings				R12M CO2e Savings (kg/yr)

Comments:

The electricity use baseline was updated for the Bridger Glade Pump Station, the baseline period is July 2021 to June 2022. The electricity baseline uses the amount of water pumped (m³) as the independent variable. The updated baseline has no baseload factor and a marginally larger variable component.

April is the eighth month in a row that the Bridger Glade Pump Station has used less electricity than expected, this is due to new supply pumps that were installed in late August 2022. The monthly EUI is less than average over the last 12 months.


Bridger Glade Pumps Electricity Use Compared to Baseline (kWh)






Bridger Glade Pump Station









Bridger Glade Pump Station





● EUI Monthly (kWh/m^3) ● EUI R12M (kWh/m^3)



Ohope Oxidation Ponds


-\$176	-998	-6%	-10,999	-131
Monthly Energy Cost Savings	Elec. Savings (kWh/mo)	Elec. Savings (%)	R12M Electricity Savings (kWh/yr)	CO2e Savings (kg/mo)
-\$1,928 R12M Energy Cost Savings				-1,446 R12M CO2e Savings (kg/yr)

Comments:

The baseline for electricity use was updated for the Ohope Oxidation Ponds, the baseline period is July 2021 to June 2022. The electricity baseline uses the amount of effluent pumped (m^3) as the independent variable. The updated baseline has a larger baseload factor and a smaller variable component.

Ohope Oxidation Ponds have used more electricity than expected in 8 of the last 12 months. Rainfall has generally been higher than usual, which may contribute to higher electricity usage. The monthly EUI has increased steadily over the past four months.


Ohope Oxidation Ponds Electricity Use Compared to Baseline (kWh)






Ohope Oxidation Ponds











Ohope Oxidation Ponds

Ohope Oxidation Ponds Energy Use Index by Month Compared to Rolling 12-Month Values



● EUI Monthly (kWh/m^3) ● EUI R12M (kWh/m^3)




Whakatane Oxidation Ponds

\$286	1,566	4%	-10,926	205
Monthly Energy Cost Savings	Elec. Savings (kWh/mo)	Elec. Savings (%)	R12M Electricity Savings (kWh/yr)	CO2e Savings (kg/mo)
-\$2,002				-1,435
R12M Energy Cost Savings				R12M CO2e Savings (kg/yr)

Comments:

The electricity use baseline was updated for the Whakatane Oxidation Ponds, the baseline period is July 2021 to June 2022. The electricity baseline combines electricity use for the NHH and TOU account and uses the effluent volumes each month (m^3) as the independent variable. The updated baseline has a smaller baseload factor and a smaller variable component.


The oxidation ponds' electricity use is less than expected in April 2023. The monthly EUI has increased above the 12 month average; however, the 12 month average EUI is trending downwards, which is good.






Whakatane Oxidation Ponds









Whakatane Oxidation Ponds

Whakatane Oxidation Ponds Energy Use Index by Month Compared to Rolling 12-Month Values



● EUI Monthly (kWh/m^3) ● EUI R12M (kWh/m^3)



McAlister Street and Rose Garden Pump Stations

-\$115	-2,160	-46%	-15,894	-283
Monthly Energy Cost Savings	Elec. Savings (kWh/mo)	Elec. Savings (%)	R12M Electricity Savings (kWh/yr)	CO2e Savings (kg/mo)
\$1,173 R12M Energy Cost Savings				-2,088 R12M CO2e Savings (kg/yr)


Comments:

The baseline for McAlister St and Rose Garden Pumps was updated, the baseline adjusts for the amount of rainfall at the Kopeopeo weather station. Expected electricity is for McAlister St and Rose Gardens combined. The baseline period uses data from July 2021 to June 2022. The updated baseline uses a smaller baseload and a marginally smaller variable component.

McAlister and Rose Garden Pumps Electricity Use Compared to Baseline (kWh)

The pump stations used more electricity than expected this month. April 2023 was a month with less rainfall, approximately 70mm of rain coincided within the billing period.


20,000 15,000






McAlister Street and Rose Garden Pump Stations













Murupara Pools



Comments:

Murupara Pools have been added to reporting in December 2022. The baseline period uses data from July 2021 to June 2022 and adjusts for ambient temperature as well as how many days in the month the pool is open or closed.

The pools are now closed for the season and are using a few kWh per day.




2023



Whakatane District Council

2020

Murupara Pools



■ Actual CO2 (kg)■ Expected CO2 (kg)

2022

2021

