


Summary

\$8,397 Monthly Energy Cost Savings	63,848 Elec. Savings (kWh/mo)	12% Elec. Savings (%)	653,128 R12M Electricity Savings (kWh/yr)	-851 CO2e Savings (kg/mo)
\$95,308 R12M Energy Cost Savings	-30,513 Gas. Savings (kWh/mo)	-78% Gas. Savings (%)	-265,983 R12M Gas Savings (kWh/yr)	582 R12M CO2e Savings (kg/yr)

Total Energy (kWh/Month)



Ohope Oxidation Ponds

Museum Research Centre

McAlister and Rose Garden Pumps

Bridger Glade Pumps

War Memorial Hall

Johnson Rd Pumps




Whakatane District Council

Summary

4,013 (8%)

5,156 (10%)




8,491 (16%)



Summary


Cumulative Energy Savings (kWh)




Note, cumulative savings are calculated starting July 2018




Summary





Note, cumulative savings are calculated starting July 2018





Civic Centre


\$617	3,786	13%	57,968	313
Monthly Energy Cost Savings	Elec. Savings (kWh/mo)	Elec. Savings (%)	R12M Electricity Savings (kWh/yr)	CO2e Savings (kg/mo)
\$10,521				4,800
R12M Energy Cost Savings				R12M CO2e Savings (kg/yr)

Comments:

Electricity use reduced in March compared to January and February, and was 13% below baseline for the month. This was mostly due to a reduction in afterhours and weekend electricity use as a result of improving schedules for HVAC systems.

Electric vehicle charging stations have been in use from March 2021, non-routine adjustments are on-going to account for the increased electricity use.


Civic Centre Electricity Use Compared to Baseline (kWh)






Civic Centre












Civic Centre






● EUI Monthly (kWh/year/m^2) ● EUI R12M (kWh/year/m^2)



Civic Centre






Aquatic Centre

-\$465 Monthly Energy Cost Savings	17,379 Elec. Savings (kWh/mo)	14% Elec. Savings (%)	210,010 R12M Electricity Savings (kWh/yr)	- 5,983 CO2e Savings (kg/mo)
\$12,425 R12M Energy Cost Savings	-36,901 Gas. Savings (kWh/mo)	-166% Gas. Savings (%)	-289,450 R12M Gas Savings (kWh/yr)	-40,828 R12M CO2e Savings (kg/yr)

Comments:

Electricity use was less than baseline in March, however this is in part due to gas being used for water heating while the outdoor pool heat pump is repaired. Gas use was higher than baseline as a result. In March 2023, the Aquatic Centre did not use any gas; when all heating equipment is operating as expected, gas is only really needed over winter months.


Aquatic Centre Electricity Use Compared to Baseline (kWh)






Aquatic Centre

Aquatic Centre Natural Gas Compared to Baseline (kWh)




Aquatic Centre Carbon Emissions Compared to Baseline (kg CO2e)






Aquatic Centre



Aquatic Centre Energy Use Index by Month Compared to Rolling 12-Month Values






Te Koputu Library

\$631 Monthly Energy Cost Savings	1,332 Elec. Savings (kWh/mo)	11% Elec. Savings (%)	10,616 R12M Electricity Savings (kWh/yr)	1,092 CO2e Savings (kg/mo)
\$3,860 R12M Energy Cost Savings	4,880 Gas. Savings (kWh/mo)	43% Gas. Savings (%)	25,587 R12M Gas Savings (kWh/yr)	6,025 R12M CO2e Savings (kg/yr)

Comments:

Gas use was 43% below baseline in March and continues a trend of lower gas use which began in October 2023 and is the result of reducing afterhours fresh air and optimising set points. There has been a focus on improving the efficiency of dehumidification which has led to electricity and gas savings. This is currently limited by the inability of the chiller to maintain an appropriate chilled water temperature due to no buffer tank and poor chiller capacity control.





Note: New Zealand was in Covid-19 alert levels 3 and 4 from 23 March until 12 May, 2020. Energy use may have been impacted during this time *Baselines were updated for all sites from July 2022.*

Actual Electricity (kWh)Expected Electricity(kWh)




Te Koputu Library












Te Koputu Library












Museum and Research Centre

\$318 Monthly Energy Cost Savings	1,681 Elec. Savings (kWh/mo)	19% Elec. Savings (%)	-1,392 R12M Electricity Savings (kWh/yr)	255 CO2e Savings (kg/mo)
-\$642 R12M Energy Cost Savings	576 Gas. Savings (kWh/mo)	20% Gas. Savings (%)	-4,028 R12M Gas Savings (kWh/yr)	-925 R12M CO2e Savings (kg/yr)

Comments:


Natural gas and electricity were 20% and 19% below baseline respectively, which is an excellent result. Electricity and gas have each reduced in the last two months which has largely been the result of optimising control of the HVAC system. The HVAC system at the Museum and Research Centre has advantages compared to the Library and Exhibition Centre because it has a chilled water buffer tank and better chiller capacity control. The energy use intensity (EUI) is consistently lower at the Museum compared to the Library.






Museum and Research Centre






Museum Research Centre Carbon Emissions Compared to Baseline (kg CO2e)






Museum and Research Centre





● EUI Monthly (kWh/year/m^2) ● EUI R12M (kWh/year/m^2)

Museum Research Centre Rolling 12 Month Savings





War Memorial Hall


\$131 Monthly Energy Cost Savings	319 Elec. Savings (kWh/mo)	8% Elec. Savings (%)	-14,787 R12M Electricity Savings (kWh/yr)	214 CO2e Savings (kg/mo)
-\$2,185 R12M Energy Cost Savings	932 Gas. Savings (kWh/mo)	38% Gas. Savings (%)	1,907 R12M Gas Savings (kWh/yr)	-841 R12M CO2e Savings (kg/yr)

Comments:

The War Memorial Hall used less electricity than baseline in March, and reduced sharply compared to February. This breaks a 7 month trend of electricity use higher than baseline.

Natural gas use was less than expected for the 6 consecutive month.


War Memorial Hall Electricity Use Compared to Baseline (kWh)






War Memorial Hall

War Memorial Hall Natural Gas Compared to Baseline (kWh)




War Memorial Hall Carbon Emissions Compared to Baseline (kg CO2e)






War Memorial Hall

War Memorial Hall Energy Use Index by Month Compared to Rolling 12-Month Values








Water Treatment Plant

\$3,761	24,525	19%	310,379	2,031
Monthly Energy Cost Savings	Elec. Savings (kWh/mo)	Elec. Savings (%)	R12M Electricity Savings (kWh/yr)	CO2e Savings (kg/mo)
\$52,017				25,699
R12M Energy Cost Savings				R12M CO2e Savings (kg/yr)

Comments:

The water treatment plan continues to achieve savings in the order of 20% each month. This is the result of upgrading high lift pumps in 2022.


Water Treatment Plant Electricity Use Compared to Baseline (kWh)






Water Treatment Plant

Water Treatment Plant Carbon Emissions Compared to Baseline (kg CO2e)








Water Treatment Plant

Water Treatment Plant Energy Use Index by Month Compared to Rolling 12-Month Values






Braemar Road Pump Station

\$247	1,588	2%	2,297	132
Monthly Energy Cost Savings	Elec. Savings (kWh/mo)	Elec. Savings (%)	R12M Electricity Savings (kWh/yr)	CO2e Savings (kg/mo)
\$501				190
R12M Energy Cost Savings				R12M CO2e Savings (kg/yr)

Comments:


Braemar Rd pump station has been re-baselined in January 2024, the baseline period is Jul 2023 to Jan 2024 and has an R2 value of 0.99. The new baseline is required to account for arsenic screening and additional pumps. Usage in March was 2% below this new baseline





Braemar Road Pump Station












Braemar Road Pump Station

Braemar Rd Pumps Energy Use Index by Month Compared to Rolling 12-Month Values



● EUI Monthly (kWh/m^3) ● EUI R12M (kWh/m^3)



Paul Road Pump Station

\$162 Monthly Energy Cost Savings	1,047 Elec. Savings (kWh/mo)	2% Elec. Savings (%)	11,310 R12M Electricity Savings (kWh/yr)	87 CO2e Savings (kg/mo)
\$2,072 R12M Energy Cost Savings				936 R12M CO2e Savings (kg/yr)

Comments:


Paul Rd pumps have not had any significant changes for the past few years and have operated with consistent efficiency. Electricity was 2% below baseline in March.

Paul Rd Pumps Electricity Use Compared to Baseline (kWh) 60,000 Actual Electricity (kWh) 40,000 20,000 January August March June March July November February September December September September December October November January February October November December January February 2022 2021 2023 2024 ◆Actual Electricity (kWh)◆Expected Electricity(kWh)




Paul Road Pump Station












Paul Road Pump Station

Paul Rd Pumps Energy Use Index by Month Compared to Rolling 12-Month Values



● EUI Monthly (kWh/m^3) ● EUI R12M (kWh/m^3)




Johnson Road Pump Station

\$647 Monthly Energy Cost Savings	2,911 Elec. Savings (kWh/mo)	42% Elec. Savings (%)	35,245 R12M Electricity Savings (kWh/yr)	241 CO2e Savings (kg/mo)
\$7,735 R12M Energy Cost Savings				2,918 R12M CO2e Savings (kg/yr)

Comments:

Johnson Rd pump operates as part of a system that includes Braemar Rd. Because the Braemar Rd pumps are more efficient than Johnson Rd, an effort has been made to minimise the use of Johnson Rd.


Johnson Rd Pumps Electricity Use Compared to Baseline (kWh)






Johnson Road Pump Station

Johnson Rd Pumps Carbon Emissions Compared to Baseline (kg CO2e)







Johnson Road Pump Station

Johnson Rd Pumps Energy Use Index by Month Compared to Rolling 12-Month Values






Johnson and Braemar Rd Pump Stations

\$894	4,500	6%	37,542	373
Monthly Energy Cost Savings	Elec. Savings (kWh/mo)	Elec. Savings (%)	R12M Electricity Savings (kWh/yr)	CO2e Savings (kg/mo)
\$8,236 R12M Energy Cost Savings				3,108 R12M CO2e Savings (kg/yr)

Comments:

Braemar Rd pump station has been re-baselined due to new pumping requirements from additional screens added, which has increased electricity use by approximately 24%.


Johnson and Braemar Rd Pump Stations Electricity Use Compared to Baseline (kWh)






Johnson and Braemar Rd Pump Stations

Johnson and Braemar Rd Pump Stations Carbon Emissions Compared to Baseline (kWh)








Johnson and Braemar Rd Pump Stations








Bridger Glade Pump Station

\$314	1,773	14%	18,751	147
Monthly Energy Cost Savings	Elec. Savings (kWh/mo)	Elec. Savings (%)	R12M Electricity Savings (kWh/yr)	CO2e Savings (kg/mo)
\$3,316 R12M Energy Cost Savings				1,553 R12M CO2e Savings (kg/yr)

Comments:

Bridger Glade Pump Station has shown savings of approximately 15% each month since new pumps were installed late in 2022. The overall efficiency of the pumps is poorer than would be expected. Further work is needed to determine if the pumps are operating near their Best Efficiency Point (BEP).


Bridger Glade Pumps Electricity Use Compared to Baseline (kWh)






Bridger Glade Pump Station









Bridger Glade Pump Station





● EUI Monthly (kWh/m^3) ● EUI R12M (kWh/m^3)




Ohope Oxidation Ponds

\$71	392	2%	-13,267	32
Monthly Energy Cost Savings	Elec. Savings (kWh/mo)	Elec. Savings (%)	R12M Electricity Savings (kWh/yr)	CO2e Savings (kg/mo)
-\$2,370 R12M Energy Cost Savings				-1,098 R12M CO2e Savings (kg/yr)

Comments:

Electricity used by the Ohope oxidation ponds in March was the lowest for any month since April 2022. This coincided with lower effluent volume, however was the first time in 12 months that electricity use was below baseline.


Ohope Oxidation Ponds Electricity Use Compared to Baseline (kWh)






Ohope Oxidation Ponds

Ohope Oxidation Ponds Carbon Emissions Compared to Baseline (kg CO2e)







Ohope Oxidation Ponds





● EUI Monthly (kWh/m^3) ● EUI R12M (kWh/m^3)




Whakatane Oxidation Ponds

\$790	1,216	4%	23,187	101
Monthly Energy Cost Savings	Elec. Savings (kWh/mo)	Elec. Savings (%)	R12M Electricity Savings (kWh/yr)	CO2e Savings (kg/mo)
\$4,779 R12M Energy Cost Savings				1,920 R12M CO2e Savings (kg/yr)

Comments:


Electricity used and effluent treated by the Whakatane Oxidation Ponds has been trending down on average for the past 18 months. Electricity use has been below baseline for eleven of the past 12 months, including a 4% saving compared to baseline in March.






Whakatane Oxidation Ponds












Whakatane Oxidation Ponds

Whakatane Oxidation Ponds Energy Use Index by Month Compared to Rolling 12-Month Values



● EUI Monthly (kWh/m^3) ● EUI R12M (kWh/m^3)




McAlister Street and Rose Garden Pump Stations

\$207	128	3%	-10,173	11
Monthly Energy Cost Savings	Elec. Savings (kWh/mo)	Elec. Savings (%)	R12M Electricity Savings (kWh/yr)	CO2e Savings (kg/mo)
¢1 107				0/2
\$1,187 R12M Energy Cost Savings				-842 R12M CO2e Savings (kg/yr)
3,				3 (37)

Comments:

McAlister Street and Rose Garden pump stations are part of a common system and are combined for energy monitoring. Electricity use is compared to a baseline using rainfall for the billing period. Electricity use was 3% below baseline overall in March.


McAlister and Rose Garden Pumps Electricity Use Compared to Baseline (kWh)







McAlister Street and Rose Garden Pump Stations













Murupara Pools




Comments:

Murupara Pools have used less electricity than expected overall this season, largely due to new pool covers that reduce evaporation and heat loss overnight. In the past two seasons, the pools have closed early or mid march. This year the pools were open to the end of March. Expected electricity increased in March due to cooler ambient temperature, however actual electricity went down slightly and was 22% below baseline for the month.





Murupara Pools



Murupara Pools Rolling 12 Month Savings

■Actual CO2 (kg)■Expected CO2 (kg)

